



*Rockwood Park Reservoir & Communications Tower
SCADA Communications Repair
July 2015*

2015 Annual Water Report



2015 Saint John Water - Annual Water Report

Table of Contents

1. INTRODUCTION.....	1
1.1. Protective Barriers	1
1.2. Annual Report	2
2. MONITORING RESULTS.....	3
2.1. Raw Water and Distribution System	3
2.2. Monitoring Results	5
3. WATER PRODUCTION.....	6
3.1. Spruce Lake System	6
3.2. Loch Lomond System.....	11
3.3. Harbourview Well System	15
3.4. Combined Systems	16
3.5. Chemical Consumption	18
4. OPERATIONAL HIGHLIGHTS.....	19
4.1. Watersheds	19
4.2. Water Quality	20
4.2.1. Boil Orders and Advisories.....	20
4.2.2. Unidirectional Flushing Program.....	23
4.2.3. Continuous Flushing Program	26
4.3. Backflow Prevention and Cross-Connection Control	26
4.4. Water Distribution	27
5. CAPITAL WATER SYSTEM IMPROVEMENTS	28
6. OPERATOR TRAINING & CERTIFICATION	29
6.1. Operator Training – Water Treatment	37
6.2. Operator Certification – Water Treatment	37
6.3. Operator Training - Water Distribution.....	38
6.4. Operator Certification - Water Distribution	39
7. HUMAN RESOURCES.....	41
7.1. Responsible Staff.....	41
7.2. New Hires	41
7.3. Staffing Changes	42



8. PUBLIC INFORMATION.....	42
8.1. Communications.....	42
8.2. Customer Service.....	43
8.3. Commitment.....	43

List of Tables

Table 2.1-1: 2015 Summarized Sampling Plan.....	4
Table 3.1-1: 2015 Annual Water Production (raw and treated) – Spruce Lake.....	7
Table 3.1-2: 2015 Peak Monthly Production (raw and treated) – Spruce Lake.....	7
Table 3.1-3: Spruce Lake System 2015 Combined – Treated and Raw Water Production.....	8
Table 3.1-4: Spruce Lake System 2015 Treated Water Production.....	9
Table 3.1-5: Musquash – Menzies Lake Interbasin Transfer.....	10
Table 3.2-1: 2015 Annual Water Production (raw and treated) – Loch Lomond System.....	11
Table 3.2-2: Loch Lomond System 2015 Combined-Domestic and Industrial Water Production.....	12
Table 3.2-3: Loch Lomond System 2015 Treated Water Production.....	13
Table 3.3-1: Harbourview Well System 2015 Treated Water Production.....	15
Table 3.4-1: Combined Daily Average Water Production.....	17
Table 3.5-1: Chemical Consumptions by Year.....	18
Table 4.2.2-1: Unidirectional Flushing Program by Year.....	24
Table 4.2.2-2: Unidirectional Flushing Program by Zone.....	25
Table 6-1: Certifications Achieved in 2015.....	36
Table 6.2-1: Water Treatment Operator Certification.....	38
Table 6.4-1: Water Distribution Operator Certification.....	40
Table 7.1-1: Saint John Water Responsible Staff.....	41
Table 7.2-1: SJ Water New Hires.....	41
Table 7.3-1: SJ Water Staffing Changes.....	42

List of Figures

Figure 3.1-1: 2015 Spruce Lake System Monthly Production.....	8
Figure 3.1-2: 2015 Spruce Lake System Monthly Treated Water Production.....	9
Figure 3.1-3: Map of Western Watersheds (Musquash and Spruce Lake).....	10
Figure 3.2-1: 2015 Loch Lomond System Monthly Production.....	12
Figure 3.2-2: 2015 Loch Lomond System Monthly Treated Water Production.....	13
Figure 3.2-3: Map of Eastern Watersheds (Latimer).....	14
Figure 3.2-4: Map of Eastern Watersheds (Loch Lomond).....	14
Figure 3.4-1: 2015 Combined System Average Daily Production.....	17
Figure 3.5-1: Sodium Hypochlorite Storage Tank – Spruce Lake WTP.....	18
Figure 3.5-2: Chlorine gas tonners being offloaded at Latimer Lake WTP.....	18
Figure 5-1: Approved Capital Water Main Improvement Plans.....	29

**APPENDICES**

- A. East & West Raw Water Sample Sites
- B. Raw Water Analytical Results
- C. Raw Water & Distribution System Organic & Inorganic Analytical Results
- D. Monthly Water Testing Summaries
- E. CoA, Water Sampling Plan with Map & ACE Review
- F. Chlorine Residual Assurance Program – Data & Graphs
- G. Chlorine Residual Data & Other Monitoring Data
- H. 2015 Approved Water and Sewerage Utility Fund Capital Program
- I. Examples of Field Test Unit Functional Check Record
- J. Certifications Achieved to Date
- K. 2015 Summary of Watermain Breaks
- L. 2015 Staff Training Summary
- M. Examples of Weekly Construction Update
- N. Public Communication
- O. Examples of 2015 Media Coverage
- P. 2015 Customer Requests Relating to Pressure & Water Quality
- Q. 2015 THM, HAA, TOC, DOC, Turbidity, Temperature, and UVT Data
- R. 2015 Cross Connection Removal Program
- S. 2015 Taste & Odour Data
- T. 2015 Water Quality Flushings Inventory
- U. 2015 Bulk Water Testing Latimer Lake and Spruce Lake



1. INTRODUCTION

Saint John Water, a department of the City of Saint John, is responsible for the delivery of three public facing services; *Drinking Water*, *Industrial Water* and *Wastewater*. The following annual report covers the Drinking Water and the Industrial Water services.

The goal of the *Drinking Water* service is to reliably supply safe, clean potable water to all users. Currently, drinking water simply receives limited treatment; coarse screening, and disinfection (chlorine gas at Latimer Lake and sodium hypochlorite at Spruce Lake). The service is regulated under the Clean Environment Act – Water Quality Regulation and Clean Water Act - Potable Water Regulation and delivered under *Approval to Operate W-669: Drinking Water Treatment and Distribution Facilities*. This *Approval to Operate* (a copy is enclosed in Appendix E) was issued by the New Brunswick Minister of the Environment effective April 1, 2011. The City's current certificate is valid for a 5-year period from April 1, 2011 to March 31, 2016. The certificate represents formal authorization to the City of Saint John (Approval Holder) by the Minister to operate drinking water facilities.

The Industrial Water service provides some industries in Saint John (namely Irving Pulp & Paper, Coleson Cove and Irving Paper) with raw industrial water to support and carry out their processes.

All municipal drinking water systems in New Brunswick are required to abide by the various conditions set out in *Approvals to Operate* drinking water treatment and distribution facilities. These regulatory tools set standards for water treatment facilities, distribution facilities, system operators and overall operation of facilities that strive to ensure safe and reliable drinking water for all users. Saint John Water fully endorses these standards and the philosophy behind the need for strict regulation of systems supplying such a vital service to the public.

1.1. Protective Barriers

People must have water to live; good health depends on consuming adequate quantities of safe, clean drinking water. That water must be delivered, at the best cost possible, to Saint John homes, institutions and businesses in a state that is clear, colourless, odourless and free of disease-causing micro-organisms (pathogens) or harmful chemicals.

The *Drinking Water Service* is a public service that provides drinking water to the community and is vital to the economic vitality of the region. This service includes the supply of water, treatment, testing, transmission and distribution, administration of the service, and billing and collections.



Saint John Water manages its drinking water service based on the Multi-Barrier Approach from the water source to the user's tap. Drinking water quality must be assured through a series of protective barriers:

1. Source (Watershed) Protection
2. Drinking Water Treatment
3. Operations and Maintenance (including staff training, development and staff levels)
4. Monitoring and Alarms (Sampling Plan, SCADA system, and record keeping)
5. Distribution System (residual chlorine maintenance, total coliform sampling , E. coli sampling, water quality flushing, storage reservoirs, backflow prevention and cross connection control)
6. Emergency Response (contingency plans, boil order responses, safety training, etc.)

1.2. Annual Report

Condition 36 of the certificate requires submission of an *Annual Report* to the Department of the Environment and Local Government. The report provides pertinent technical and operating information to the regulator on the City's water systems including:

- Monitoring results (daily/weekly/monthly data such as free chlorine residual, turbidity, pH, temperature, iron, manganese, etc.)
- Monthly water production
- Operational highlights (significant incidents and system improvements, changes, or additions);
- Alarm log (major alarms – the balance to be discussed during formal Compliance Evaluations)
- Summary of backflow prevention and cross-connection activities;
- Summary of flushing activities;
- Operator information (training, certifications, and staffing changes);
- Public relations (notifications & public education)
- List of major new extensions and/or renewals complete with analytical results (microbiological, organic& inorganic) and the balance to be discussed during formal Compliance Evaluations
- Additional comments

